




electrical mfg. company

9131 - 10th Avenue South Seattle Washington 98108

INSTALLATION & MAINTENANCE MANUAL

KBP2406-3MP 240V 1-3phase

KBP2006-3MP 208V 1-3phase



WARNING

This KBP2406-3MP is 240 Volt and the KBP2006-3MP is 208 Volt. It is important you verify your power supply voltage is the same as the nameplate voltage of the heater. Improper installation or failure to follow the procedures as outlined in this manual can result in damage to the heater. Note that the KBP2406-3MP will operate at 208 Volt but will produce 25% less wattage and draw 13% less Amps. Both these models can be field-wired for 1-Phase or 3-Phase (refer to the wiring diagram on back page). Disconnect all power from the heater at the main service panel before attempting to install or service this unit. All electrical wiring must conform to local electrical codes. Heater circuit must be properly protected.

Unpack & Inspect Your New Heater

Remove heater from box and inspect for any damage. Verify you have received the mounting bracket and accessories.

Tools Needed

You will need the following tools to install your unit heater:

- screwdriver (Phillips head & slotted)
- wire cutters
- pliers
- adjustable wrench
- electric drill

Hardware Needed

You will also need the following hardware:

- adequate gauge & length of wire for your application.
- proper size fuses or breakers to handle amperage.
- proper wire connectors for your application.
- fasteners appropriate size to mount heater.

In certain applications conduit may be required by code. Check local electrical codes. If you want to be able to turn the heater be sure to use flexible conduit.

Mounting Height

When the air flow of the heater is directed vertically or horizontally the minimum mounting height is 6 feet (8 feet in Canada). Mounting heights depend upon building utilization and heater kW capacity.

Distance From Walls


Be sure to maintain 6" minimum clearance to side walls and 2" to ceiling and wall in back of the heater (air intake side).

Mounting Heater

Locate a stud in ceiling or wall and securely fasten bracket with a minimum of two #12 fasteners 1-1/4" long. Attach heater to bracket with 3/8" x 1" wing nut & lock washer supplied. Install the lock washer between the bracket and heater, do not put lock washer on the plastic wing nut. After desired air discharge position has been determined, tighten wing nut so that heater will not pivot.

Location of Heater

The heater should be installed out of the reach of persons. The direction of air flow should not be restricted by machinery, beams, etc., and the air flow should wipe exposed walls, rather than blowing directly at them. When more than one heater is used in an area, the heaters should be arranged so that the air discharge of each heater supports the air flow of the others to provide best circulation of warm air. (See Air Flow Chart)



Wiring Heater


WARNING - Before proceeding further with the installation of this heater, turn off the power and lock the supply line for the heater at the main service panel.

1. Remove wiring compartment cover.
2. Remove one of the knockouts from back of unit. It is not necessary to remove grill covers.
3. Size service wire to adequately handle Amp load of heater. Refer to the Circuit Sizing Table for proper wire size and circuit protection.
4. Connect supply wire to L1, L2 & L3 for 3-Phase or L1 and L3 for 1-Phase as shown in the diagram below. Connect to the lugs on the line side of the contactor.
5. Secure power supply cable with clamps.
6. Connect groundwire to the green pigtail.
7. Reinstall wiring compartment cover.
8. Adjust the heater to the desired position.

CIRCUIT SIZING TABLE					
Watts	BTUH	Volts	Amps 1-Phase	Wire Size	Circuit Protection
1,900	6,484	208 240	9.1 7.9	#14 / 2	15A - 2P
2,850	9,727	208 240	13.7 11.9	#12 / 2 #14 / 2	20A - 2P 15A - 2P
3,800	12,969	208 240	18.3 15.8	#10 / 2 #12 / 2	30A - 2P 20A - 2P
4,750	16,211	208 240	22.8 19.8	#10 / 2	30A - 2P
5,700	19,454	208 240	27.4 23.7	#8 / 2 #10 / 2	40A - 2P 30A - 2P
Watts	BTUH	Volts	Amps 3-Phase	Wire Size	Circuit Protection
2,850	9,727	208 240	7.9 6.8	#14 / 3	15A - 3P
5,700	19,454	208 240	15.8 13.7	#12 / 3	20A - 3P

* Per the National Electric code heating circuits are considered a continuous load and therefore must be derated by 20%. For example: a 20 Amp heating circuit cannot have more than 16 Amps of load connected.

3-Phase to 1-Phase Diagram



1. Factory wired for 3-Phase.
2. For conversion to 1-Phase:
 - a) Move wire **X - Black** from T2 to T1.
 - b) Move wire **Y - Red** from T2 to T3.
 - c) Make power connections to L1 & L3.


Field Wattage Selection

1. 3-Phase

- a) 5700 Watts factory wired
- b) 2850 Watts - disconnect **B, E, H**

2. 1-Phase

- a) 5700 Watts factory wired
- b) 4750 Watts - disconnect **H**
- c) 3800 Watts - disconnect **H, B**
- d) 2850 Watts - disconnect **H, B, E**
- e) 1900 Watts - disconnect **H, C, E, A**



KBP2406-3MP and KBP2006-3MP

1900 • 2850 • 3800 • 4750 • 5700
WATTAGES AVAILABLE IN ONE UNIT

